

CERTIFICATE OF CONFORMITY

This Certificate is issued to

G-CAST CONCRETE SDN BHD

**Chin Hin Building Materials, Menara Chin Hin, Level 22-23, 8th & Stellar,
No 1, Jalan Naga Emas, Sri Petaling 57000 Kuala Lumpur**

For Product Certification Scheme: Type 5

Product : Reinforced Concrete Pipe and Manholes Item

Brand : G-CAST

Model : CLASS H

Country of Origin : Malaysia

Product Details : Refer to Appendix for details.

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

SS 183: 1978

TEST REPORT(S)

SETSCO Test Report No.: MM-8500391629/YPS/1

SETSCO Test Report No.: MM-8500391629/YPS/2

SETSCO Test Report No.: MM-8500391629/YPS/3

Detailed configuration and installation shall be referenced to the certified report(s) stated above.

SETSCO



Teo Wee Hwee (Mr)
Program Manager
SETSCO Services Pte Ltd

Certificate No
BCM-2026-0088

Date of Issue
12/02/2026

Date of Expiry
11/02/2029

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

| Type | Butt Join Pipe Class "H" |
|-------------------------|--|
| Test Report | SETSCO MM-8500391629/YPS/1 SETSCO MM-8500391629/YPS/2 SETSCO MM-8500391629/YPS/3 |
| Internal Diameter | 450 – 1650 mm |
| External Diameter | 530 – 1880 mm |
| Wall thickness of pipe | 40 – 113 mm |
| Cover Diameter | - |
| Measured length of pipe | Max 3050 mm |
| Dimension Measurement | Satisfactory |
| Crushing Strength Test | Satisfactory |



Teo Wee Hwee (Mr)
Program Manager
SETSCO Services Pte Ltd

Certificate No
BCM-2026-0088

Date of Issue
12/02/2026

Date of Expiry
11/02/2029

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.