

# CERTIFICATE OF CONFORMITY

This Certificate is issued to

## G-CAST CONCRETE SDN BHD

Chin Hin Building Materials, Menara Chin Hin Level 22-23, 8th & Stellar No1,  
Jalan Naga Emas, Sri Petaling 57000 Kuala Lumpur, Malaysia

For Product Certification Scheme: Type 5

**Product** : Reinforced Concrete Pipe and Manholes Item

**Brand** : G-CAST

**Model** : CLASS H

**Country of Origin** : Malaysia

**Product Details** : Refer to Appendix for details.

which has complied with the requirements of the scheme based on the following:

### STANDARD(S)

SS 183:1978

### TEST REPORT(S)

SETSCO Test Report No.: MM-8500374578/YPS/1-1  
SETSCO Test Report No.: MM-8500374578/YPS/1-3  
SETSCO Test Report No.: MM-8500374578/YPS/1-5  
SETSCO Test Report No.: MM-8500374578/YPS/1-7  
SETSCO Test Report No.: MM-8500374578/YPS/2-1  
SETSCO Test Report No.: MM-8500374578/YPS/2-2  
SETSCO Test Report No.: MM-8500374578/YPS/2-3

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



**Teo Wee Hwee (Mr)**  
Program Manager  
SETSCO Services Pte Ltd

**Certificate No**  
**BCM-2025-0086**

**Date of Issue**  
**22/10/2025**

**Date of Expiry**  
**21/10/2028**

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at [www.setsco.com](http://www.setsco.com)

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

Type	R.C. chamber ring, Class “H”	Top Slab Manhole Chamber Ring
Test Report	MM-8500374578/YPS/1-1 MM-8500374578/YPS/1-3 MM-8500374578/YPS/1-5 MM-8500374578/YPS/1-7	MM-8500374578/YPS/2-1 MM-8500374578/YPS/2-2 MM-8500374578/YPS/2-3
Internal Diameter	1050 – 2100 mm	-
External Diameter	1250 – 2470 mm	-
Wall thickness of pipe	100 – 182 mm	-
Cover Diameter	-	1400 - 2200
Measured length of pipe	600 – 1500 mm	250
Dimension Measurement	Satisfactory	Satisfactory
Crushing Strength Test	Satisfactory	Satisfactory



**Teo Wee Hwee (Mr)**  
Program Manager  
SETSCO Services Pte Ltd

**Certificate No**  
**BCM-2025-0086**

**Date of Issue**  
**22/10/2025**

**Date of Expiry**  
**21/10/2028**

*Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.*