

CERTIFICATE OF CONFORMITY

This Certificate is issued to

G-CAST CONCRETE SDN BHD

**Chin Hin Building Materials, Menara Chin Hin, Level 22-23, 8th & Stellar
No1, Jalan Naga Emas, Sri Petaling 57000 Kuala Lumpur, Malaysia**

For Product Certification Scheme: Type 5

Product : Reinforced Concrete Pipe

Brand : G-Cast

Model : Jacking Pipe

Country of Origin : Malaysia

Product Details : Refer to Appendix for details.

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

BS 5911-1: 2002
BS EN 1916: 2002

TEST REPORT(S)

SETSCO Test Report No.: MM-53804/YPS/1
SETSCO Test Report No.: MM-58301/YPS/1
SETSCO Test Report No.: MM-8500100818/YPS/1
SETSCO Test Report No.: MM-8500097247/YPS

Detailed configuration and installation shall be referenced to the certified report(s) stated above.

SETSCO



Teo Wee Hwee (Mr)
Program Manager
SETSCO Services Pte Ltd

Certificate No

BCM-2016-0021_R1_2509

Date of Issue

23/09/2025

Date of Expiry

11/08/2028

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

Type	Class: 120 with 330 HDPE lining	Class: 120 without HDPE lining
Test Report	MM-8500100818/YPS/1 MM-8500097247/YPS	MM-53804/YPS/1 MM-58301/YPS/1
Internal Diameter	900mm - 1350mm	750mm - 2500mm
External Diameter	1250mm - 1600mm	960mm - 3040mm
Wall thickness of pipe	125mm - 175mm	105mm - 270mm
Measured length of pipe	2920mm	2920mm
Crushing Strength Test	Satisfactory	Satisfactory
Surface Finish Test	Satisfactory	Satisfactory
Joint Assembly Test	Satisfactory	Satisfactory
Depth of Covering	Satisfactory	Satisfactory
Drilled Core Strength	Satisfactory	Satisfactory
Water Absorption Test	Satisfactory	Satisfactory



Teo Wee Hwee (Mr)
Program Manager
SETSCO Services Pte Ltd

Certificate No
BCM-2016-0021_R1_2509

Date of Issue
23/09/2025

Date of Expiry
11/08/2028

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.